# 



RISK OF FIRE AND ELECTRICAL SHOCK. FIXTURE MUST BE INSTALLED BY A QUALIFIED ELECTRICIAN ONLY IN ACCORDANCE WITH NATIONAL, LOCAL BUILDING AND ELECTRICAL CODES. DISCONNECT POWER AT ELECTRICAL PANEL BEFORE SERVICING.

### 12100-20 | 12100-40 - INSTALLATION INSTRUCTIONS FOR PENDANT-CABLE MOUNT



Run Aircraft cable(E) through Grip lock installed on fixture and adjust height by pushing Grip lock.



# 12100-20 | 12100-40 - INSTALLATION INSTRUCTIONS FOR PENDANT-CABLE MOUNT

# **CONTINUES ROW**

#### TOOL(S) NEEDED:

Option 1) Cordless drill and an elbow or L-shape adapter with Philips Insert Bit extension.





Option 2) Flexible Screwdriver with Philips Insert Bit.



1) Make wiring connection from each fixture power supply wires together.

2) Align fixtures and screw together with 4 screws(H).



# 

# 12100-20 | 12100-40 - INSTALLATION INSTRUCTIONS FOR PENDANT-CABLE MOUNT

