

INSTALLATION INSTRUCTIONS

Read instruction manual carefully to ensure proper installation.
Keep this instruction manual.

WARNING:



RISK OF FIRE AND ELECTRICAL SHOCK. FIXTURE MUST BE INSTALLED BY A QUALIFIED ELECTRICIAN ONLY IN ACCORDANCE WITH NATIONAL, LOCAL BUILDING AND ELECTRICAL CODES. DISCONNECT POWER AT ELECTRICAL PANEL BEFORE SERVICING.

WARNING:



To avoid the risk of fire or electric shock, this product must be installed, inspected, and maintained only by a qualified electrician. Installation must be performed by an individual familiar with the construction and operation of the luminaire. Installation must comply with national and local building and electrical codes.

Safety Warning

To avoid electric shock:

Be certain electrical power is OFF before and during installation and maintenance. Luminaire must be supplied by a wiring system with an equipment grounding conductor.

To avoid burning hands:

Make sure lens and housing are cool before performing maintenance.

To avoid product degradation:

Make sure the supply voltage matches the luminaire's rated voltage. Use proper supply wiring as specified on the luminaire nameplate. Avoid use in environments containing sulfur, chlorine, or other halides, methyl acetate, ethyl acetate, cyanoacrylates, glycol ethers, formaldehyde, or butadiene.

Notes


These instructions do not cover all details and all possible product configurations. Do not restrict luminaire ventilation. Ensure the LED luminaire is not covered with material that will prevent convection or conduction cooling. Verify correct polarity before installation. Avoid exposing wiring to metal edges and sharp objects.

Maintenance


Perform visual, electrical, and mechanical inspections on a regular basis; frequency should be determined by the operating environment and usage, with checks recommended at least once per year. Electrically, verify that all connections are clean and tight. Mechanically, verify that all parts are properly assembled.

Key fixes: added missing spaces after commas throughout, fixed "wire supply voltage is the same as the luminaire supply" (incomplete comparison) to "matches the luminaire's rated voltage," corrected the run-on Oxford comma list in the chemical exposure warning, and grouped related notes into complete sentences rather than fragments.


WIRING DIAGRAM




DIP SWITCH FOR CCT




INSTALLATION DIMENSIONS PENDANT MOUNT




SURFACE MOUNT



PENDANT MOUNT




INSTALLATION DIMENSIONS PENDANT MOUNT (UP & DOWN LIGHTING VERSION)




CONNECTION-A



1. Connect the fixture on the back first




Step 1: take off the lens and end cap





2. take off reflector



2. Connect the inner cap together



Step1: use the screw 3xUNC8-32 connect the inner end c



CONNECTION-B

