


## IMPORTANT SAFETY INFORMATION:

- Make sure that the supply voltage corresponds to the rated product voltage.
- The product must be installed by a qualified electrician in accordance with the National Electrical Code and corresponding local codes.

#### **CHAIN MOUNT**

- Insert V-hooks into both ends of the fixture. Secure chain to ceiling, beam or other mounting surface. Use screwdriver to open the plate.
- 2. Open the top knockout with a screwdriver. Screw the plate back.
- 3. Connect the wiring in accordance to the wiring diagram in these specifications. If you are not using the dimming, wires cap them off but not together.
- 4. Reattach knockout plate to top of the fixture.





#### **POLE MOUNT**


# MOUNTING BRACKET (SOLD SEPARATELY)



Pendant mounting bracket allows for easy 3/4 NPT installation. Bracket does not include nut or screw for mounting to surface.

#### **INSTALLATION STEPS**


- 1. Install the mounting bracket on 3/4 NPT pipe.
- 2. Use a screw driver to attach bracket to center of the fixture.
- 3. Connect the wiring in accordance to the wiring diagram in these specifications. If you are not using the dimming wires, cap them off but not together.
- 4. Lock side brackets with screwdriver.






## **SURFACE MOUNT**

# MOUNTING BRACKET (SOLD SEPARATELY)






- 1. Bolt the brackets to ceiling, beam, joist or rail. (bolts not included).
- 2. Connect the wiring in accordance to the wiring diagram in these specifications. If you are not using the dimming wires cap them off but not together.
- 3. Attach the fixture to the bracket. 2 screws per each side of the bracket.










## Emergency Back Up Battery Kit

## (SOLD SEPARATELY)


- Open the wiring compartment of the highbay (unscrew the back plate, remove knockouts, take the wires out, screw the plate back). Remove the cover of the EM driver (4 screws)
- 2. Attach the driver to the back of the highbay with 4 screws, pull the wires out. Connect the driver to the panel following the diagram below.
- 3. Reverse the fixture, take the center panel down. Remove 2 knockouts in the middle of the panel for indicator light and test button install.
- 4. Pull indicator light and test button from the emergency driver to the front of the fixture, install them into the front cover. Screw the front panel back to the fixture.
- Connect the fixture to power as it's shown in the diagram below, attach the cover of the EM driver. Installation is complete.



# **EMERGENCY-KIT WIRING DIAGRAM**

# SWIICH I SO-277 V SO/60 H I ED DRIVER I E

#### 165 W, 220 W, 300 W



110 W