


## 14086-6 - 2200lm - 4000K

System Power	:31W	Multipliers	
Test Date	:12/2015	3500K	0.99
Beam Angle 50%	:78.0°	3000K	0.97
Field Angle 10%	:123.9°		
Color Temperature:	4000K		
CRI	:80		
R9 Value	:68		
Lumens Delivered	:2220lm		
CBCP	:1455cd		
Power Factor	:1.00		

## CANDELA TABULATION



## FOOTCANDLE DISTRIBUTION

Height	Beam Diameter	FC
8'	12.5'	22.7
9'	14.0'	18.0
10'	15.6'	14.6
12'	18.7'	10.1
15'	23.4'	6.5

## RECOMMENDED SPACING

Clg Ht	Spacing	Max/Min Ratio
10 ft	7.5 ft o.c.	4.3:1
12 ft	6.5 ft o.c.	1.8:1
15 ft	5 ft o.c.	1.5:1

## EFFECTIVE FLOOR CAVITY REFLECTANCE @ 20%

RC	80	50	30	10
RW	70	50	30	10
0	119	119	119	119
1	111	107	104	101
2	103	97	91	87
3	96	88	81	76
4	89	80	72	67
5	83	73	65	60
6	78	67	59	54
7	73	61	54	49
8	69	57	49	44
9	65	53	46	41
10	61	49	42	37

RC	50	30	10
RW	70	30	10
0	111	111	111
1	101	99	96
2	92	87	84
3	83	78	74
4	76	70	65
5	70	63	59
6	64	58	53
7	59	53	48
8	55	49	44
9	51	45	40
10	48	42	37

RC	70	50	30	10
RW	70	50	30	10
0	116	116	116	116
1	109	105	102	99
2	101	95	90	86
3	94	86	80	75
4	87	78	72	66
5	82	72	65	59
6	76	66	59	53
7	72	61	54	48
8	67	56	49	44
9	63	52	45	41
10	60	49	42	37